

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
JEFFERSON SMURFIT CORP.
(CONSTRUCTION OF SUPPLY WELL)

NPDES NO. CAG994001
CI-8297

FACILITY ADDRESS

Jefferson Smurfit Corp.
2001 E. 57th Street
Los Angeles, CA 90058

FACILITY MAILING ADDRESS

Jefferson Smurfit Corp.
2001 E. 57th Street
Los Angeles, CA 90058

PROJECT DESCRIPTION

Jefferson Smurfit, a paper recycler, proposes to install a 1,000 ft deep industrial supply well. Groundwater will be discharged to a storm drain during the set-up and development of this well.

VOLUME AND DESCRIPTION OF DISCHARGE

Up to 1 million gallons per day for a total of 4.8 million gallons will be discharged over a period of four or five days to the storm drain (Latitude: 33° 59' 29"N, Longitude: 118° 14' 08"W). An environmental survey of nearby industrial sites found no records of contamination of groundwater. Discharge from the storm drain flows to the Los Angeles River, a water of the United States. The well and outfall locations are shown in Figure 1, attached.

FREQUENCY OF DISCHARGE

Discharge will occur over a period of four or five days.

REUSE OF WATER

During the well start-up much more water will be produced than can be used in the recycling processes; so while a small amount of the water may be used in industrial processing, the majority of the water will have to be discharged to the storm drain.